



STATE OF MAINE
DEPARTMENT OF HUMAN SERVICES
AUGUSTA, MAINE 04333

DAVID E. SMITH
COMMISSIONER

September 10, 1976

Mr. Richard Baker
Local Plumbing Inspector
City Hall
Augusta, Maine 04330

Subject: Dumont Subdivision, Middle Road, Augusta

Dear Sir:

This is to acknowledge the receipt of a waiver request by Mr. Paul Lindberg, P.E. for lots No. 1A, and 2A, (formerly 1, 2, and 3). The proposal is to install a 20' x 70' bed in fill.

Based on the information submitted, this office has no alternative but to disallow the installation of a subsurface sewage disposal system on the system on the subject property, due to non-conformance with Section 4.3, Maine Plumbing Code, Part II.

Yours very truly,

A handwritten signature in cursive script, reading 'W. C. Toppan'.

W. Clough Toppan, Sanitary Engineer
Plans & Standards Review
Division of Health Engineering

WCT/cm
cc: Leon Dumont