

SUBSURFACE WASTEWATER DISPOSAL SYSTEM APPLICATION

08027524

Town, City, Plantation

Street, Road, Subdivision

Owner's Name

AUGUSTA


LYON RD

MAGHELL JOHNSON

SITE PLAN

Scale: 1" = 50 Ft.
or as shown

SITE LOCATION PLAN
(Attach Map from Maine Atlas
for New System Variance)



SOIL DESCRIPTION AND CLASSIFICATION

(Location of Observation Holes Shown Above)

Observation Hole 1 Test Pit Boring
2' " Depth of Organic Horizon Above Mineral Soil

Inches	Texture	Consistency	Color	Mottling
0	LOAM	FRIABLE	DARK BR.	NONE
6	SILTY		YELLOW	
10	LOAM		BR.	
15	SILTY			
20	CLAY	FIRM	GRAY	COMMON DISTINCT
30				
40				
50				

Soil Classification: 9C Slope: 0% Limiting Factor: 16 Ground Water Restr. Layer Bedrock

Profile Condition: C

Observation Hole 2 Test Pit Boring
22' " Depth of Organic Horizon Above Mineral Soil

Inches	Texture	Consistency	Color	Mottling
0				
6				
10				
15				
20				
20	SAME AS #1			
30				
40				
50				

Soil Classification: _____ Slope: _____ Limiting Factor: _____ Ground Water Restr. Layer Bedrock

Profile Condition: _____

[Signature]
Site Evaluator Signature

256
SE#

8/01/97
Date

Approved for use as
HHE 200 by Division of
Health Engineering 9/87

SUBSURFACE WASTEWATER DISPOSAL SYSTEM APPLICATION

08246445

Town, City, Plantation

Street, Road, Subdivision

Owner's Name


AUGUSTA

LYON RD.

MACHELL JOHNSON

SUBSURFACE WASTEWATER DISPOSAL PLAN

Scale: 1" = 20' Ft.
or as shown



FILL REQUIREMENTS
 Depth of Fill (Upslope) 20"
 Depth of Fill (Downslope) 20"


CONSTRUCTION ELEVATION
 Reference Elevation is 20"
 Bottom of Disposal Area 20"
 Top of Distribution Lines or Chambers 0"

ELEVATION REFERENCE POINT
0" ERP IN 12" MAPLE 7'
-56" EAST OF SYSTEM, 48"
-45" ABOVE GROUND

DISPOSAL AREA CROSS SECTION

Scale:

Vertical: 1 inch = 5 Ft.
 Horizontal: 1 inch = 10 Ft.



[Signature]
 Site Evaluator Signature

256
 SE#

8/01/97
 Date

Approved for use as
 HHE 200 by Division of
 Health Engineering 9/87