

GARY M3 L38A

CEM

SUBSURFACE WASTEWATER DISPOSAL SYSTEM APPLICATION

Department of Human Services
Division of Water Engineering
(207) 287-3872 FAX (207) 287-4172

PROPERTY LOCATION

Town or Plantation: **AUGUSTA**

St. Subdivision Lot: **CHURCH HILL RD**

AUGUSTA
Date Permit Issued: **5.8.98**

3921 TOWN COPY
\$ **120.00** FEE Double Fee Charged

L.P.I. # **850**

[Signature]
Local Plumbing Inspector Signature

PROPERTY OWNER'S NAME

Last: **TRASK** First: **EDWARD**

Applicant's Name: **R-1 B-1056**

Mailing Address of Owner: **AUGUSTA, ME 04330**

Daytime Tel.: **682-0737**

Municipal Tax Map: **3** Lot: **38A**

Owner Statement

I state that the information submitted is correct to the best of my knowledge and understand that any falsification is reason for the Department and/or Local Plumbing Inspector to deny a permit

[Signature]
Signature of Owner/Applicant

Date: _____

Caution: Inspection Required

I have inspected the installation authorized above and found it to be in compliance with the Subsurface Wastewater Disposal Rules Application

[Signature]
Local Plumbing Inspector Signature

Date Approved: **6-5-98**

PERMIT INFORMATION

TYPE OF APPLICATION:

- First Time System
- Replacement System
Type Replaced: **1965 FRENCH**
Year Installed: **1965**
- Expanded System
 a. one time exempted
 b. non exempted
- Experimental System
 Seasonal Conversion

THIS APPLICATION REQUIRES:

- No Rule Variance
- First Time System Variance
 a. Local Plumbing Inspector approval
 b. State & Local Plumbing Inspector approval
- Replacement System Variance
 a. Local Plumbing Inspector approval
 b. State & Local Plumbing Inspector approval
- Minimum Lot Size Variance
- Seasonal Conversion Approval

DISPOSAL SYSTEM COMPONENT(S)

- Non-Engineered System
- Primitive System (graywater & oil toilet)
- Alternative Toilet _____
- Non-Engineered Treatment Tank
- Holding Tank _____ Gallons
- Non-Engineered Disposal Area (only)
- Separated Laundry System
- Engineered System (>2000 gpd)
- Engineered Treatment Tank (only)
- Engineered Disposal Area (only)
- Pretreatment

SIZE OF PROPERTY

18,000 sq ft

DISPOSAL SYSTEM TO SERVE:

- Single Family Dwelling Unit
- Multiple Family Dwelling: Number of Units _____
- Other _____

TYPE OF WATER SUPPLY

DRILLED WELL

SHORELAND ZONING

Yes No

DESIGN DETAILS (SYSTEM LAYOUT SHOWN ON PAGE 3)

TREATMENT TANK

- Concrete
 a. Regular
 b. Low Profile
- Plastic
- Other _____

SIZE: **1000** Gallons

DISPOSAL AREA TYPE / SIZE

- Bed **800** Sq. Ft.
- Proprietary Device _____ Sq. Ft.
 Cluster Linear
 Regular H-20
- Trench
- Other _____

GARBAGE DISPOSAL UNIT

- No
- Yes
 Multi-compartment tank
 Tank in series
 Increase in tank capacity
 Filter on tank outlet

CRITERIA USED FOR DESIGN FLOW
(Show Calculations)

2 BEDROOMS @ 120 GPD EACH.

DESIGN FLOW: **240**
(Gallons/Day)

PROFILE & DESIGN CLASS

PROFILE: **3** DESIGN: **A/C**

DEPTH TO MOST LIMITING FACTOR: **30/18**

DISPOSAL AREA SIZING

- Small - 2.00
- Medium - 2.60
- Medium-Large - 3.30
- Large - 4.10
- Extra-Large - 5.20

PUMPING

- Not required
- May be required
- Required

DOSE: _____ Gallons

SITE EVALUATOR'S STATEMENT

On **4/21/98** (date) I completed a site evaluation on this property and state that the data reported is accurate and that the proposed system is in compliance with the Subsurface Wastewater Disposal Rules.

[Signature]
Site Evaluator Signature

WILLIAM W. RIDEOUT
Site Evaluator Name Printed

51
SE

(207) 582-4161
Telephone

4/22/98
Date

SUBSURFACE WASTEWATER DISPOSAL SYSTEM APPLICATION

Department of Human Services
Division of Health Engineering
(207) 287-3672 FAX (207) 287-4172

Town, City, Plantation
AUGUSTA

Street, Road Subdivision
CHURCH HILL RD


Owner's Name
TRASK

SITE PLAN

Scale 1" = 30 Ft.
or as shown

SITE LOCATION PLAN
(Map from Maine Atlas recommended)

Box 1056
 CHURCH HILL RD 2.2 MI
 RT 3



SOIL DESCRIPTION AND CLASSIFICATION (Location of Observation Holes Shown Above)

Observation Hole 1 Test Pit Boring
 " Depth of Organic Horizon Above Mineral Soil

Observation Hole Test Pit Boring
 " Depth of Organic Horizon Above Mineral Soil

DEPTH BELOW MINERAL SOIL SURFACE (inches)	Texture	Consistency	Color	Mottling
0	S.L.	FRIABLE	B	
10				
20				18
30	G.T.	FIRM	G.B.	
40	POSSIBLE BEDROCK 30"			
50				

DEPTH BELOW MINERAL SOIL SURFACE (inches)	Texture	Consistency	Color	Mottling
0				
10				
20				
30				
40				
50				

Soil Classification 3 B/C Slope 8 % Limiting Factor 30/18
 Ground Water Restrictive Layer Bedrock Pit Depth

Soil Classification _____ Slope _____ % Limiting Factor _____
 Ground Water Restrictive Layer Bedrock Pit Depth

Uma W. Rideout
Site Evaluator Signature


51
SE

4/22/98
Date

SUBSURFACE WASTEWATER DISPOSAL PLAN

Scale 1" = 20' FL

MAY 18 1988



APPROX. TOE 4:1 FILL

3-4" x 30' PVC PERFORATED PIPE CONNECTED AT ENDS
20' x 40' BED

FILL REQUIREMENTS

Depth of Fill (Upslope) 18"
Depth of Fill (Downslope) 40"


CONSTRUCTION ELEVATIONS

Reference Elevation Is 0
Bottom of Disposal Area -70"
Top of Distribution Lines or Chambers -59"


ELEVATION REFERENCE POINT LOCATION & DESCRIPTION

0
-70" TOP OF BOTTOM STEP
-59" OF DECK = 0"

- ① 3" TOPSOIL CROWNED 3%
- ② 8" CLEAN SAND
- ③ 2" COMPACTED HAY
- ④ 12" CLEAN STONE 1-1/2" REC



Scale:
Vertical: 1 inch = 5 ft.
Horizontal: 1 inch = 10 ft.



FILL MATERIAL TO BE LOAMY SAND
GRUB SURFACE - REMOVE ORGANICS

Site Evaluator Signature

51

SE#

4/22/88

Date

REPLACEMENT SYSTEM VARIANCE REQUEST

RECEIVED

THE LIMITATIONS OF THE REPLACEMENT SYSTEM VARIANCE REQUEST

This form shall be attached to an application (HHE-200) for the proposed replacement system which requires a variance to the Rules. The LPI shall review the Replacement System Variance Request on HHE-200 and may approve the Request if all of the following requirements can be met, and the variance(s) requested fall within the limits of LPI's authority.

1. The proposed design meets the definition of a Replacement System as defined in the Rules (Sec. 1903)
2. There will be no change in use of the structure except as authorized for one-time exempted expansions outside the shoreland zone of major waterbodies/courses.
3. The replacement system is determined by the Site Evaluator and LPI to be the most practical method to treat and dispose of the wastewater.
4. The BOD₅ plus S.S. content of the wastewater is no greater than that of normal domestic effluent.

GENERAL INFORMATION

Town of AUGUSTA

Permit No. _____

Date Permit Issued _____

Property Owner's Name: EDWARD TRASK

Tel. No.: 622-0737

System's Location: CHURCH HILL RD

Property Owner's Address: _____

(if different from above) _____

SPECIFIC INSTRUCTIONS TO THE:
LOCAL PLUMBING INSPECTOR (LPI):

If any of the variances exceed your approval authority and/or do not meet all of the requirements listed under the Limitations Section above, then you are to send this Replacement System Variance Request, along with the Application, to the Department for review and approval consideration before issuing a Permit. (See reverse side for Comments Section and your signature.)

SITE EVALUATOR:

If after completing the Application, you find that a variance for the proposed replacement system is needed, complete the Replacement Variance Request with your signature on reverse side of form.

PROPERTY OWNER:

If has been determined by the Site Evaluator that a variance to the Rules is required for the proposed replacement system. This variance request is due to physical limitations of the site and/or soil conditions. Both the Site Evaluator and the LPI have considered the site/soil restrictions and have concluded that a replacement system in total compliance with the Rules is not possible.

PROPERTY OWNER

I understand that the proposed system requires a variance to the Rules. Should the proposed system malfunction, I release all concerned provided they have performed their duties in a reasonable and proper manner, and I will promptly notify the Local Plumbing Inspector and make any corrections required by the Rules. By signing the variance request form, I acknowledge permission for representatives of the Department to enter onto the property to perform such duties as may be necessary to evaluate the variance request.

Annie Trask

5-8-98

SIGNATURE OF OWNER

DATE

LOCAL PLUMBING INSPECTOR

I, [Signature], the undersigned, have visited the above property and have determined to the best of my knowledge that it cannot be installed in compliance with the Rules. As a result of my review of the Replacement Variance Request, the Application, and my on-site investigation, I (check and complete either a or b):

a. (approve, disapprove) the variance request based on my authority to grant this variance. Note: If the LPI does not give his approval, he shall list his reasons for denial in Comments Section below and return to the applicant. -OR-

b. find that one or more of the requested Variances exceeds my approval authority as LPI. I (recommend, do not recommend) the Department's approval of the variances. Note: If the LPI does not recommend the Department's approval, she shall state his reasons in Comments Section below as to why the proposed replacement system is not being recommended.

Comments: _____

[Signature]

5/8/98

LPI SIGNATURE

DATE

Replacement System Variance Request

VARIANCE CATEGORY	VARIANCE REQUESTED		LIMIT OF LPI'S APPROVAL AUTHORITY		VARIANCE REQUESTED TO:	
SOILS						
Soil Profile	Ground Water Table		to 7"		_____ Inches	
Soil Condition	Restrictive Layer		to 7"		_____ Inches	
from HHE-200	Bedrock		to 12"		_____ Inches	
SETBACK DISTANCES (in feet)	Disposal Fields		Septic Tanks		Disposal Fields	Septic Tanks
From	Less than 1000 gpd	1000 to 2000 gpd	Less Than 1000 gpd	1000 to 2000 gpd	To	To
Wells with water usage of 2000 or more gpd	300 ^a ft	300 ^a ft	100 ^a ft	100 ^a ft	_____	_____
Owner's wells	100 down to 50 ft	200 down to 100 ft	100 ^b down to 50 ft	100 down to 50 ft	60'±	50't
Neighbor's wells	100 ^b down to 60 ft	200 ^b down to 120 ft	100 ^b down to 50 ft	100 ^b down to 75 ft		
Water supply line	10 ft ^d	20 ft ^d	10 ft ^d	10 ft ^d		
Water course, major - for replacements only, see Table 400.4 for exempted expansions	100 down to 60 ft	200 down to 120 ft	100 down to 50 ft	100 down to 50 ft		
Water course, minor	50 down to 25 ft	100 down to 50 ft	50 down to 25 ft	50 down to 25 ft		
Drainage ditches	25 down to 12 ft	50 down to 25 ft	25 down to 12 ft	25 down to 12 ft		
Coastal wetlands, special freshwater wetlands, great ponds, rivers, streams (edge of fill extension)	25 ft ^d	25 ft ^d	25 ft ^d	25 ft ^d		
Slopes greater than 3:1	10 ft	18 ft	N/A	N/A		
No full basement [e.g. slab, frost wall, columns]	15 down to 7 ft	30 down to 15 ft	8 down to 5 ft	14 down to 7 ft		
Full basement [below grade foundation]	20 down to 10 ft	30 down to 15 ft	8 down to 5 ft	14 down to 7 ft		
Property lines	10 down to 5 ^c ft	18 ft down to 9 ^c ft	10 ft down to 4 ^c ft	15 ft down to 7 ^c ft		
Burial sites or graveyards, measured from the down toe of the fill extension	25 ft	25 ft	25 ft	25 ft		

OTHER

1. _____
2. _____
3. _____

Footnotes:

- a. This setback distance cannot be reduced by the LPI, but may be considered for reduction by State variance.
- b. Written Permission from the owner of a well is required when a replacement system will be located less than 100 (or 200 ft. for 1000-2000 gpd) feet and closer to that well than the system it is replacing.
- c. Sufficient distance shall be maintained to assure that the toe of the fill does not extend to the 3:1 slope or property line.
- d. Natural Resources Protection Act requires a 25 foot setback on slopes with less than 20% from the edge of disturbance and 100 feet on slopes greater than 20% except for the repair or installation of a replacement system when no practical alternative exists.

Umar W. Redean

 SITE EVALUATOR'S SIGNATURE

8/22/98

 DATE

FOR USE BY THE DEPARTMENT ONLY

The Department has reviewed the variance(s) and () does () does not) give its approval. Any additional requirements, recommendations, or reasons for the Variance denial, are given in the attached letter.

 SIGNATURE OF THE DEPARTMENT

 DATE