

SUBSURFACE WASTEWATER DISPOSAL SYSTEM APPLICATION

05017627

Town, City, Plantation

Street, Road, Subdivision

Owner's Name

AUGUSTA

R# 3

BOB


RYNOLDS

SITE PLAN

Scale: 1" = 50 Ft. or as shown

SITE LOCATION PLAN

(Attach Map from Maine Atlas for New System Variance).



SOIL DESCRIPTION AND CLASSIFICATION (Location of Observation Holes Shown Above)

Observation Hole 1 Test Pit Boring
0 " Depth of Organic Horizon Above Mineral Soil

Inches	Texture	Consistency	Color	Mottling
0	SANDY	FRIABLE	DARK BR.	NOVIE
6	LOAM			
10	GRAVELY		YELLOW	
15	LOAMY		BR.	
20	SAND			
20		FIRM	GRAY	COMMON
30				
40				
50				

Soil Classification: 3 Profile, C Condition
 Slope: 4 %
 Limiting Factor: 18"
 Ground Water
 Restr. Layer
 Bedrock

Observation Hole 2 Test Pit Boring
0 " Depth of Organic Horizon Above Mineral Soil

Inches	Texture	Consistency	Color	Mottling
0				
6				
10				
15				
20				
30	SAME AS #1			
40				
50				

Soil Classification: Profile, Condition
 Slope: %
 Limiting Factor: %
 Ground Water
 Restr. Layer
 Bedrock

[Signature]
 Site Evaluator Signature

256 SE#

5/2/97 Date

Approved for use as HHE 200 by Division of Health Engineering 9/87

SUBSURFACE WASTEWATER DISPOSAL SYSTEM APPLICATION

08116004


Town, City, Plantation
AUGUSTA

Street, Road, Subdivision
RT # 3

Owner's Name
BOB RYNOLDS

SUBSURFACE WASTEWATER DISPOSAL PLAN

Scale: 1" = 20 Ft.
or as shown




FILL REQUIREMENTS
Depth of Fill (Upslope)
Depth of Fill (Downslope)

CONSTRUCTION ELEVATION
18" Reference Elevation is
27" Bottom of Disposal Area
Top of Distribution Lines or Chambers

ELEVATION REFERENCE POINT
0" E.R.P. IN 2' APPLE 18'
-64" WEST OF SYSTEM, 2'4" ABOVE GROUND
-53"

DISPOSAL AREA CROSS SECTION

Scale:
Vertical: 1 inch = 5 Ft.
Horizontal: 1 inch = 10 Ft.



[Signature]
Site Evaluator Signature

256
SE#

5/2/97
Date

Approved for use as
HHE 200 by Division of
Health Engineering 9/87