Small, William

STATE OF MAINE
DEPARTMENT OF HEALTH AND WELFARE
AUGUSTA, MAINE 04330

DEAN FISHER, M. D.
COMMISSIONER

June 28, 1972

Mr. Ralph Waning, L.S.
Box 84
Vassalboro, ME 04989

Subject: Percolation Test for William Small
Three-Cornered Pond, Augusta
Reported Undated

Dear Mr. Waning:

After review of the subject percolation test, we find that it does not appear to have been made in compliance with instructions in the Code. The rate is to be measured in the bottom six inches of the hole.

It is important that the directions be followed carefully, otherwise, the test results are not reliable and may not be acceptable.

Yours very truly,

Earle W. Tibbetts, Director
Division of Health Engineering

JLF/tma

cc: Charles Morton, L.P.I.