Dostie, Pamphile

STATE OF MAINE
DEPARTMENT OF HUMAN SERVICES
AUGUSTA, MAINE 04333

DAVID E. SMITH
COMMISSIONER

November 22, 1978

Mr. Pamphile Dostie
200 Mount Vernon Avenue
Augusta, ME 04330

Subject: Waiver to the Maine Plumbing Code, Part II, Pamphile Dostie property, Burns Road, Augusta

Dear Sir:

This will acknowledge receipt of a waiver request and a plan with soils information by Gerald C. Poulin, SE., showing the proposed sewage disposal system for the subject project. It is not in compliance with the Maine Plumbing Code, Part II, because of the installation of two beds, each 66'x10' on 9D soils with mottling at 13 inches, an impervious layer at 17 inches and on a slope of 11-12 percent, the reason for the waiver request. Size of lot is approximately 150 feet x 500 feet.

After a careful review of all information submitted, this office has no alternative but to deny the waiver request. This office normally follows a policy of considering waivers to the Maine Plumbing Code, Part II, only in cases of existing overboard discharges, or the replacement of existing malfunctioning sewage disposal systems, where full compliance with the code is not possible.

Yours very truly,

Russell G. Martin, Sanitary Engineer
Plans & Standards Review
Division of Health Engineering

DPB/lh
cc: Gerald Poulin, SE
Richard Baker, LPI
enc.