QUIRION, EDMUND

SUBMIT THE FOLLOWING COMPLETED FORM TO YOUR LOCAL PLUMBING INSPECTOR

DATE 6/28/74	OWNER Edmund J. Quirion Lot 11
NUMBER OF BEDROOMS 3	STREET W. River Rd.
SIZE OF SEPTIC TANK 1000	CITY Augusta MAINE
TYPE OF SOIL Gravel	TELEPHONE NUMBER 622-6784
Test Performed by	LOCATION OF PROPOSED INSTALLATION
Rolfe's Plumbing & Heating #1620	STREET Patrick St.
Local Plumbing Inspector Signature	CITY Augusta MAINE
George L. Smith	TELEPHONE NUMBER

SKETCH: LOCATION OF BUILDING DISPOSAL SYSTEM, TERRAIN FEATURES, PERCOLATION HOLES, WATER SUPPLIES, ETC.



Patrick St.

5+ Depth to water table

5+ Depth to bedrock

5+ Depth to layer of other impervious strata

REMARKS

HOLE	HOLE DEPTH	TIME START	TIME FINISH	DEPTH OF WATER SURFACE START	DEPTH OF WATER SURFACE FINISH	ELAPSED TIME	TOTAL DROP OF WATER	PERCOL. RATE MINUTES/INCH
#1	36 in.	11:40	12:40	34 in.	16 in.	60 min.	18 in.	3.3-1 min/in
#2	36 in.	11:45	12:45	34 in.	16 in.	60 min.	18 in.	3.3-1 min/in
#3	36 in.	11:50	12:50	34 in.	15 in.	60 min.	19 in.	3.2-1 min/in
#4	36 in.	11:55	12:55	34 in.	19 in.	60 min.	15 in.	4-1 min/in
						AVERAGE RATE		3.5-1 min/in