QUIRION, EDMOND

SUBMIT THE FOLLOWING COMPLETED FORM TO YOUR LOCAL PLUMBING INSPECTOR

DATE 6/28/74
NUMBER OF BEDROOMS 3
CALF OF SEPTIC TANK 1000
TYPE OF SOIL Gravel
Test Performed by
Rolfe's Plumbing & Heating #1620
Local Plumbing Inspector's Signature
George L. Smith

OWNER Edmund J. Quirion Lot 19
STREET W. River Rd.
CITY Augusta MAINE
TEL. NUMBER 622-6784

LOCATION OF PROPOSED INSTALLATION
STREET Patrick St.
CITY Augusta MAINE
TEL. NUMBER

SKETCH: LOCATION OF BUILDING DISPOSAL SYSTEM, TERRAIN FEATURES, PERCOLATION HOLES, WATER SUPPLIES, ETC.



Patrick St.

5+ Depth to water table
5+ Depth to bedrock
5+ Depth to clay or other impervious strata

REMARKS

HOLE	HOLE DEPTH	TIME START	TIME FINISH	DEPTH OF WATER SURFACE START	DEPTH OF WATER SURFACE FINISH	ELAPSED TIME	TOTAL DROP OF WATER	PERCOL. RATE MINUTES/INCH
#1	36 in.	11:20	12:20	34 in.	16 in.	60 min.	18 in.	3.3-1 min/in
#2	36 in.	11:25	12:25	34 in.	17 in.	60 min.	17 in.	3.5-1 min/in
#3	36 in.	11:30	12:30	34 in.	19 in.	60 min.	15 in.	4-1 min/in
#4	36 in.	11:35	12:35	34 in.	16 in.	60 min.	18 in.	3.3-1 min/in

AVERAGE RATE 3.5-1 min/in