ST. Amand, Reg. Ward

FORM FOR REPORTING PERCOLATION TEST

	Name	Address	Telephone Number
Owner	Reginald R. St. Amand	Ward Rd	Augusta

	Type	Address	Telephone Number
Building	frame	Ward Rd.	Augusta

Number of apartments _____ Bedrooms per apartment _____

Proposed size of septic tank (gallons) 750-900 Gallon Soil Type Sandy-Loam Rocky

Read depth from ground level down to surface of water.

	1	2	3	4
Hole#	1	2	3	4
Depth	36"	36"	36"	36"
First Reading	30"	30"	28"	30"
Time	9:00 AM	9:05 AM	9:05 AM	9:10 AM
Last Reading	34"	34"	32"	34"
Time	9:20 AM	9:25	9:25	9:30
Rate (minutes per inch)	5 min	5 min	5 min	5 min

	5	6	7	8
Hole#				
Depth				
First Reading				
Time				
Last Reading				
Time				
Rate (minutes per inch)				

STATE OF MAINE J. ROBERT CURTIS 870 REGISTERED LAND SURVEYOR

Test performed by J. Robert Curtis (Signature) August 5. 1972 (Date)

Note:
Indicate hole locations on back of sheet.
If more holes are required, use additional sheet.
For test procedure, consult sheet SE 80, or Appendix C of the Plumbing Code.
For private house, deliver results to Local Plumbing Inspector.
For commercial establishments, mail results to
Sanitary Engineering
Department of Health and Welfare
State House, Augusta, Maine 04330

Note

Size of Lot

200 x 435' ±

2 Acres



STATE OF MAINE
ROBERT DURTIS 570
REGISTERED LAND SURVEYOR

Scale 1" = 100' ±

Robert Curtis