



STATE OF MAINE
DEPARTMENT OF HEALTH AND WELFARE
AUGUSTA, MAINE 04330

DAVID E. SMITH
COMMISSIONER

May 13, 1975

*Soil Tests
for 1975*

Wright Woolston and Turner
460 Main Street
Lewiston, ME 04240

Subject: Restaurant Facility, Augusta State Airport,
Augusta, Maine, Interior Plumbing

Dear Sir:

A review of plan dated March 26, 1975, and specifications for a proposed restaurant facility located at the Augusta State Airport, has been completed by this office. Sewage disposal and water supply lines will connect to existing sewer and water lines in the building which are served by public utility.

Based on the written information you submitted, the proposed design does not appear to meet requirements of State of Maine Rules and Regulations Relating to Eating Establishments. However, discrepancies are of such a nature that we hereby give preliminary approval. Our final approval will be dependent upon correction of these discrepancies listed below and submission to this office of revised plans showing corrections have been made. Pertinent portions of the regulations are cited relative to the discrepancies.

Section 5.6 of the above mentioned regulations requires that a lavatory for handwashing be located within the area where food is prepared, in addition to the lavatory required in the toilet room.

As an added note, Sheet P-1 indicates that two indirect waste receptors are being used. If any of the indirect waste pipes discharging into these receptors is greater than 15 feet in length, it must be separately vented as required in Section 603 of the Maine Plumbing Code, Part I.

When corrected plans are submitted for our examination we will be happy to review for our final approval.

Yours very truly,

for Russell S. Tharpe

W. Clough Toppan, Sanitary Engineer
Plans and Standards Review
Division of Health Engineering

RGM/mm

cc: Thomas Gordon, LPI
James Datsis