Harlow Bldg.
AMHI

May 17, 1979

Mr. Phil Rose
c/o Bureau of Public Improvements
State House
Augusta, ME 04333

Subject: Rehabilitation of Harlow Building, Augusta Mental Health Institute, Augusta

Dear Mr. Rose:

This letter is being written in reply to your visit to this office in our review of the plans for the Harlow Building on May 15, 1979. It is our understanding that the existing facilities and fixtures in the Harlow Building on the first, second and third floors are to be cut approximately in half and new fixtures connected to most of the existing piping. Some additional piping and bending of angles may have to be done in order to incorporate this remodeling as indicated by you in this office. We have no objections to the rehabilitation provided all plumbing and/or additional piping conforms with the State Plumbing Code, Part I.

Final approval is subject to permit by the Local Plumbing Inspector before the construction of this system. The inspector is to be notified before covering the work, and the work is to be left uncovered until his inspection. He shall be supplied with copies of approved plans for his reference at inspection. Approval is also subject to any local ordinances and state laws.

Very truly yours,

David P. Breau
Plans & Standards Review
Division of Health Engineering

DPB/lh
cc: Richard Baker, LPI