

GASS, STEPHEN



STATE OF MAINE
DEPARTMENT OF HUMAN SERVICES
AUGUSTA, MAINE 04333

DAVID E. SMITH
COMMISSIONER

September 30, 1977

Stephen Gass
7 Brooklawn Avenue
Augusta, Maine 04330

Subject: Waiver to the Maine Plumbing Code, Part II,
Stephen Gass property, Route 17, Augusta

Dear Sir:

This will acknowledge receipt of a waiver request and a plan with soils information by Darryl N. Brown, Site Investigator, showing the replacement sewage disposal system for the existing malfunction. It is not in compliance with the Maine Plumbing Code, Part II, because of a disposal system proposed on non-discharge soil type, the reason for the waiver request.

After a careful review of all information submitted, this office has no alternative but to deny the waiver request. This office normally follows a policy of considering waivers to the Maine Plumbing Code, Part II, only in cases of existing overboard discharges, or the replacement of existing malfunctioning sewage disposal systems, where full compliance with the code is not possible.

This office can see no way a conventional disposal system can function at the proposed site and suggests that a new location with more suitable soil conditions be found.

Yours very truly,

Russell G. Martin, Sanitary Engineer
Plans and Standards Review
Division of Health Engineering

DWP/mm

cc: Richard Baker, LPI
Darryl N. Brown
Freeman Eugley