SOIL INVESTIGATION

TOWN OF AUGUSTA

Soil Profile No. P1	Soil Profile No. P2
Owner: Allenwood Parking GUY ALLEN	Owner: Allenwood Parking GUY ALLEN
Map No. ALLENWOOD PARK Lot No. 32	Map No. ALLENWOOD PARK Lot No. 32
Date: May 11, 1985	Date: May 11, 1985
Thickness and Description of each soil strata encountered: 2"-0" DUFF; 0"-5" RED BROWN SANDY LOAM; 5"-17" BROWN SANDY LOAM	Thickness and Description of each soil strata encountered: 1"-0" DUFF; 0"-10" RED BROWN SANDY LOAM; 10"-16" BROWN SANDY LOAM
Depth from bot. of organic horizon to:	Depth from bot of organic horizon to:
Maximum Ground Water Table inches none evident ☒	Maximum Ground Water Table 16 inches none evident ☐
Impervious Layer inches none evident ☒	Impervious Layer inches none evident ☒
Bedrock Type inches none evident ☒	Bedrock Type inches none evident ☒
Slope:	Slope:
Soil Type: 2 OR 3 C	Soil Type: 2 OR 3C
Comments: A 3 bedroom home on this type of soil would require a Leach field 20' x 45'	Comments:

Lic. Site Evaluator # 154
David P. Rogue Certified Soil Scientist #181