SOIL INVESTIGATION

TOWN OF AUGUSTA

Soil Profile No. P1	Date: May 11, 1985
Owner: Allenwood Parking GUY ALLEN	
Map No. ALLEN WOOD PARK Lot No. 36	
Thickness and Description of each soil strata encountered	
3"-0" Duff	
0"-16" RED BROWN SANDY LOAM	
Depth from bot. of organic horizon to:	
Maximum Ground Water Table inches none evident ☒	
Impervious Layer inches none evident ☒	
Bedrock Type inches none evident ☒	
Slope:	
Soil Type: 2 or 3C	
Comments: A 3 bedroom home on this type of soil would require a 20'x45' leach field.	

Soil Profile No. P2	Date: May 11, 1985
Owner: Allenwood Parking GUY ALLEN	
Map No. ALLEN WOOD PARK Lot No. 36	
Thickness and Description of each soil strata encountered	
3"-0" Duff	
0"-9" RED BROWN SANDY LOAM	
9"-15" BROWN SANDY LOAM	
Depth from bot. of organic horizon to:	
Maximum Ground Water Table inches none evident ☒	
Impervious Layer inches none evident ☒	
Bedrock Type inches none evident ☒	
Slope:	
Soil Type: 2 or 3C	
Comments:	

David P. Roque Lic. Site Evaluator #154
Certified Soil Scientists #181