SOIL INVESTIGATION

TOWN OF AUGUSTA

Soil Profile No. P1	Date: May 11, 1985	Date: May 11, 1985	Soil Profile No. P2
Owner: Allenwood Parking GUY ALLEN			Owner: Allenwood Parking GUY ALLEN
Map No. ALLEN WOOD PARK Lot No. 39			Map No. ALLEN WOOD PARK Lot No. 39
2"-0" Duff	Thickness and Description of each soil strata encountered	Thickness and Description of each soil strata encountered	2"-0" Duff
0"-17" RED BROWN SANDY LOAM			0"-12" RED BROWN SANDY LOAM
			12"-16" BROWN SANDY LOAM
Maximum Ground Water Table inches none evident ☒	Depth from bot. of organic horizon to:	Depth from bot. of organic horizon to:	Maximum Ground Water Table inches none evident ☒
Impervious Layer inches none evident ☒			Impervious Layer inches none evident ☒
Bedrock Type inches none evident ☒			Bedrock Type inches none evident ☒
Slope:			Slope:
Soil Type:			Soil Type:
Comments: A 3 bedroom home ON this type of Soil would require a 20'x45' Leach field.			Comments:

David P. Rogers Lic. Site Evaluator #154 Certified Soil Scientist #181