



DAVID E. SMITH
COMMISSIONER

STATE OF MAINE
DEPARTMENT OF HUMAN SERVICES
AUGUSTA, MAINE 04333

WHITNEY, DENNIS

June 16, 1976

Mr. Dennis Whitney
522 Riverside Drive
Augusta, ME 04330

Subject: Waiver to Maine Plumbing Code, Part II,
Whitney Property, Riverside Drive, Augusta

Dear Sir:


This will acknowledge receipt of a plan plus soils information by Gerald Poulin, P.E., showing the proposed sewage disposal system for the subject project. It is not in compliance with the Maine Plumbing Code, Part II because of (1) setback from septic tank to a water supply line, (2) depth to bedrock, and (3) depth of fill required, the reasons for the waiver request.

In consideration of the plan dated May 19, 1976, and recommendations by Mr. Poulin, this office will grant the responsible Local Plumbing Inspector the right to waive certain provisions of the Maine Plumbing Code for the following disposal system under authority of Section 3.14:

1. The installation of a 1000 gallon septic tank to be followed by a raised 20' X 50' disposal bed. The installation is to follow the plan submitted with this proposal.
2. The septic tank shall be located at least 5 feet from the water supply line. The septic tank shall be tested and found water tight prior to covering.
3. Fill shall be placed as specified on the attached letter by Gerald Poulin dated May 24, 1976.
4. In all other respects the installation is to comply with the Maine Plumbing Code, Part II, Private Sewage Disposal Regulations.

Final approval of the sewage portion is subject to permit by the Local Plumbing Inspector before the construction of this system. A completed HHE-200 Form must be submitted to him for processing. The inspector is to be notified before covering the work, and the work is to be left uncovered until his inspection. He shall be supplied with copies of approved plans for his reference at inspection. Approval is also subject to any local ordinances.

Yours very truly,


W. Clough Toppan, Sanitary Engineer
Plans and Standards Review
Division of Health Engineering

RGM/mm
cc: Richard Baker, LPI
Freeman Eugley
encl.