

Roque, Ventura

APPLICATION AND AGREEMENT

TO WAIVE CERTAIN PROVISIONS OF THE PLUMBING CODE

I, VENTURA ROQUE, hereby apply to the Maine State Department of Human Services for permission authorizing the responsible Plumbing Inspector to waive certain provisions of the Plumbing Code for an installation in connection with a dwelling or building at TOGUS POND ROAD, AUGUSTA.
(owner) (street) (city or town)

This may include materials, methods, dimensions or conditions not specifically approved by the Plumbing Code. Please draw a brief sketch of the property's location on the back of this form so an inspector can find it. Include landmarks, route numbers and street names.

Section of Code to be waived.	Description of specific waiver
1. 4.7	LESS THAN 100' FROM TOGUS POND (80')
2.	
3.	

(If additional space is needed, attach a list)

In all other respects, the installation will comply with the Code. The installation will be made in accordance with the ATTACHED PLAN. A permit is to be issued by the Plumbing Inspector if he is in agreement. The undersigned stipulates that he is the owner and occupant of the building involved and that the building is not for sale in the foreseeable future. The installation will be made by:

_____, License No. _____.

If any defects or inadequacies appear, I will promptly notify the State Department of Human Services and subsequently make such corrections as the Department shall find necessary

Owner's signature Ventura Roque

NOTE: A PLAN TO SCALE
MUST BE ATTACHED

Winter address R.F.D # 7, Augusta Me. 04330

Summer address SOMY.

Telephone 225172 Date MAY 25-77.

THE FOLLOWING TO BE FILLED IN BY THE PLUMBING INSPECTOR

I am (Local), (~~Alternate~~) Plumbing Inspector for the town of AUGUSTA. I have examined the plans for the installation described above and I find the building to be in my jurisdiction.

I (do), (~~do not~~) recommend the issuance of a special permit for the installation as described above.

Replacement only

Signed Richard P. Baber

Date 5-26-77

Return this form to the Division of Health Engineering, Department of Human Services, Augusta, Maine. NO permit shall be issued for this waiver until the Local Plumbing Inspector receives notification from this office.

REPLACEMENT

ORIGINAL To be sent to Division of Health Engineering, Augusta, Maine 04333 by the LPI

MAINE DEPARTMENT OF HUMAN SERVICES APPLICATION FOR PRIVATE SEWAGE DISPOSAL PERMIT		(For systems disposing of less than 2000 gallons per day)	This is NOT a permit; this form when completed must be presented to the Local Plumbing Inspector to obtain a permit.	Page 1 of 2
Town: AUGUSTA	Street, Road, etc.: TOGUS POND RD	Permit No.: 21607M	Date: 5-26-77	
Owner of property: VENTURA ROCQUE		Owner's address: TOGUS POND RD AUG.	Size of lot: 360 x 240	<input checked="" type="radio"/> Sq. feet <input type="radio"/> Acres
Name & type of establishment if other than private home: _____		gpd: _____	Is lot Zoned? <input type="radio"/> Yes <input checked="" type="radio"/> No	Type of Zoning: <input type="radio"/> Shoreland <input type="radio"/> Resource Protection
Name of applicant Owner's agent: SAME		If you plan to use a previous subdivision approval in lieu of site investigation, please submit one of the following: <input type="radio"/> Deed restriction re. private sewage disposal <input type="radio"/> Copy of the subdivision's soils report <input type="radio"/> Soils report from a State Agency		
Applicant's address Street, Box, etc.: SAME		Tel. No.: 622-5172		
Town: AUGUSTA	zip code: 04330	Subdivision name: _____	Lot No.: _____	
Applicant's signature: <i>Ventura Rocque</i>		Date: MAY 23 '77		
Owner's signature: _____		Date: _____		

This application is for: New System Expanded System Replacement System Replacement of Treatment Tank Only Disposal Area Only

The water supply for this property is: Dug well, depth _____, lining _____; Drilled well, depth: **200**, lining _____; Spring Surface water Body, Course— with disinfection, without disinfection. Public Utility, name _____


Soil Profile No.	Soil Profile No. 1		Soil Profile No. 2		Soil Profile No.		Soil Profile No.		Soil Profile No.	
	<input type="checkbox"/> Pit	<input checked="" type="checkbox"/> Boring	<input type="checkbox"/> Pit	<input checked="" type="checkbox"/> Boring	<input type="checkbox"/> Pit	<input type="checkbox"/> Boring	<input type="checkbox"/> Pit	<input type="checkbox"/> Boring	<input type="checkbox"/> Pit	<input type="checkbox"/> Boring
Thickness of each soil	1st strata: GRAVEL FILL		1st strata: SAND FILL		1st strata: _____		1st strata: _____		1st strata: _____	
	Inches: 43"		Inches: 44"		Inches: _____		Inches: _____		Inches: _____	
	2nd strata: ROCKY FILL		2nd strata: ROCKY FILL		2nd strata: _____		2nd strata: _____		2nd strata: _____	
	Inches: 12-18"		Inches: 16"		Inches: _____		Inches: _____		Inches: _____	
Depth from bottom of organic horizon to:	2nd strata: MARLB CLAY		2nd strata: _____		2nd strata: _____		2nd strata: THESE ARE SNOWEL		2nd strata: _____	
	Inches: ?		Inches: _____		Inches: _____		Inches: INCHES		Inches: _____	
	3rd strata: _____		3rd strata: _____		3rd strata: _____		3rd strata: _____		3rd strata: _____	
	Inches: _____		Inches: _____		Inches: _____		Inches: _____		Inches: _____	
Total Depth of observation hole	Inches: 56		Inches: 58		Inches: _____		Inches: _____		Inches: _____	
	Max. Ground water table—mottling: 40"		Max. Ground water table—mottling: 39"		Max. Ground water table—mottling: _____		Max. Ground water table—mottling: _____		Max. Ground water table—mottling: _____	
	Impervious layer, clay, etc.: 43"		Impervious layer, clay, etc.: 44"		Impervious layer, clay, etc.: _____		Impervious layer, clay, etc.: _____		Impervious layer, clay, etc.: _____	
	Bedrock: <input checked="" type="radio"/> None Evident		Bedrock: <input checked="" type="radio"/> None Evident		Bedrock: <input type="radio"/> None Evident		Bedrock: <input type="radio"/> None Evident		Bedrock: <input type="radio"/> None Evident	
Surface slope: 2%		Surface slope: 2%		Surface slope: _____%		Surface slope: _____%		Surface slope: _____%		
Soil Group & Condition per Table 9-1 of the Code, II: G-B		Soil Group & Condition per Table 9-1 of the Code, II: 7-C		Soil Group & Condition per Table 9-1 of the Code, II: _____		Soil Group & Condition per Table 9-1 of the Code, II: _____		Soil Group & Condition per Table 9-1 of the Code, II: _____		

On **MAY 18 77** (date), a site investigation for this project was completed. I conducted this soil evaluation and certify that the results indicated above best represent the soil conditions found. I recommend the following type and size of private sewage disposal system. I also recommend the proposed private sewage disposal system layout and location shown on page 2.

Signature: *Calvin J. Parker*
GEOLOGIST #3
 Date signed: **MAY 24**
 Health Engineering License No. **063**

PRIVATE SEWAGE DISPOSAL SYSTEM PROPOSED

SYSTEM: <input checked="" type="radio"/> COMBINED SYSTEM <input type="radio"/> SEPARATED SYSTEM If separated system—type of human waste disposal system to be used: <input type="radio"/> Sealed Vault Privy <input type="radio"/> Open Pit Privy <input type="radio"/> Compost Toilet <input type="radio"/> Incinerator Toilet <input type="radio"/> Chemical Toilet <input type="radio"/> Other, describe _____ See Chapter 9 of the Code, II.	TREATMENT TANK: <input checked="" type="radio"/> Septic Tank <input type="radio"/> Concrete <input type="radio"/> Fiberglass <input type="radio"/> Metal Size in gallons: 1000 <input type="radio"/> Aerobic Tank Manufacturer— Model No. Size in gallons	SUBSURFACE ABSORPTION AREA		SITE MODIFICATION Fill will be: 18 in. uphill; 17 in. downhill
		Type: <input type="radio"/> Trench System: Total trench length _____ <input checked="" type="radio"/> Bed System Length: 40 Width: 20 <input type="radio"/> Chamber System Number: _____ <input type="radio"/> Type A <input type="radio"/> Single File <input type="radio"/> Type B <input type="radio"/> Cluster <input type="radio"/> Mound System Length _____ Width _____ at base <input type="radio"/> Special System Length _____ Width _____ WAIVER <input checked="" type="radio"/> Required <input type="radio"/> Not Required		SIZE: <input type="radio"/> Very Small <input type="radio"/> Small <input type="radio"/> Medium <input type="radio"/> Medium Large <input type="radio"/> Large <input type="radio"/> Extra Large
DISTANCES <input type="radio"/> Yes <input checked="" type="radio"/> No: The proposed subsurface absorption area will be located at least 100 feet from any and all wells; springs; surface water bodies and courses (lake, pond, ocean, brook, stream, river); swamps; marshes; and bogs. <input type="radio"/> Yes <input type="radio"/> No: The proposed subsurface absorption area will be located at least 300 feet from any and all wells and springs producing 2000 gallons or more of water per day and any public water supplies.				



FOR THE USE OF LPI ONLY

Denial: Application is denied for following reasons; portions of the Code II are cited. Form is incomplete (____ pg.) as to General info, Site Investigation, System Proposed, Site Plan, Disposal System Plan, Cross-Section, Statement. See Section 2.3.

Site Investigation indicates site is totally unsuitable for disposal system; Sections 4.5 and 9.5, Table 9-1 Group 9 and 10. Unsuitable for system proposed; Sections 4.3, 4.6, 9.5, Table 9-1.

System Proposed does not conform to Code; See Sections 9.

Site Investigation indicates site modifications are necessary; See Sections 4.3, 4.4, 4.6, 8.7.

Miscellaneous _____ See Section _____

Acceptance: Application for permit is approved with condition specified, comply with Section **4.7**
 without condition.


Signed LPI: *Michael P. Baber* Date: **5-26-77** HHE-200 5/76

APPLICATION FOR PRIVATE SEWAGE DISPOSAL PERMIT
(For systems disposing of less than 2000 gallons per day)

Town AUGUSTA	Street, Road, etc. TOGUS POND RD If on water body, give name TOGUS POND	Owner of property VENTURA ROCQUE
------------------------	--	--


Site Plan

Scale 1" = 100 Ft. or
← CAUSEWAY




Private Sewage Disposal Plan

Scale 1" = 20' or



Subsurface Absorption Area Cross-section

Scale: Vertical - 1" = 5' or
Horizontal - 1" = 20' or



Statement: (no permit may be issued unless signed)

I certify that all the information submitted to be true and correct; and I understand that issuance of a permit based upon the information and plans submitted by the applicant. I also understand that any falsification of this application is reason to deny a permit to install a private sewage disposal system and that the permit is valid a six (6) month period from the date of permit issuance. I understand that no guarantee is intended or implied on of any advice or approval given by the Administrative Authority or its agent.

Signature Required

Date: 5-26-77

Applicant: _____

Owner: Ventura Rocque