

# SUBSURFACE WASTEWATER DISPOSAL SYSTEM APPLICATION

PROPERTY ADDRESS	
Town Or Plantation	<u>Sheldon</u>
Street	<u>Maple Road</u>
Subdivision Lot #	
PROPERTY OWNERS NAME	
Last:	First:
Applicant Name:	<u>Michael J. Brown</u>
Mailing Address of Owner/Applicant (If Different)	<u>1000 S. Main St</u>

M71 L2

AUGUSTA PERMIT # 8731 TOWN COPY

Date Permit Issued: 10/3/04 \$ 200.00 FEE  if Double Fee Charged

[Signature] L.P.I. # 8081

Local Plumbing Inspector Signature

**Owner/Applicant Statement**

I certify that the information submitted is correct to the best of my knowledge and understand that any falsification is reason for the Local Plumbing Inspector to deny a Permit.

[Signature] \_\_\_\_\_ Date: \_\_\_\_\_

Signature of Owner/Applicant

**Caution: Inspection Required**

I have inspected the installation authorized above and found it to be in compliance with the Subsurface Wastewater Disposal Rules.

\_\_\_\_\_ Date Approved

Local Plumbing Inspector Signature

## PERMIT INFORMATION

<p><b>THIS APPLICATION IS FOR:</b></p> <ol style="list-style-type: none"> <li><input type="checkbox"/> NEW SYSTEM</li> <li><input type="checkbox"/> REPLACEMENT SYSTEM</li> <li><input type="checkbox"/> EXPANDED SYSTEM</li> <li><input type="checkbox"/> SEASONAL CONVERSION</li> <li><input type="checkbox"/> EXPERIMENTAL SYSTEM</li> </ol>	<p><b>THIS APPLICATION REQUIRES:</b></p> <ol style="list-style-type: none"> <li><input type="checkbox"/> NO RULE VARIANCE REQUIRED</li> <li><input type="checkbox"/> NEW SYSTEM VARIANCE Attach New System Variance Form</li> <li><input type="checkbox"/> REPLACEMENT SYSTEM VARIANCE Attach Replacement System Variance Form</li> <li><input type="checkbox"/> Requires only Local Plumbing Inspector Approval</li> <li><input type="checkbox"/> Requires both State and Local Plumbing Inspector Approval</li> </ol>	<p><b>INSTALLATION IS COMPLETE SYSTEM</b></p> <ol style="list-style-type: none"> <li><input type="checkbox"/> NON-ENGINEERED SYSTEM</li> <li><input type="checkbox"/> PRIMITIVE SYSTEM (Includes Alternative Toilet)</li> <li><input type="checkbox"/> ENGINEERED (+ 2000 gpd)</li> </ol> <p><b>INDIVIDUALLY INSTALLED COMPONENTS:</b></p> <ol style="list-style-type: none"> <li><input checked="" type="checkbox"/> TREATMENT TANK (ONLY)</li> <li><input type="checkbox"/> HOLDING TANK</li> <li><input type="checkbox"/> ALTERNATIVE TOILET (ONLY)</li> <li><input type="checkbox"/> NON-ENGINEERED DISPOSAL AREA (ONLY)</li> <li><input type="checkbox"/> ENGINEERED DISPOSAL AREA (ONLY)</li> <li><input type="checkbox"/> SEPARATED LAUNDRY SYSTEM</li> </ol>
<p><b>IF REPLACEMENT SYSTEM:</b></p> <p>YEAR FAILING SYSTEM INSTALLED _____</p> <p>THE FAILING SYSTEM IS:</p> <ol style="list-style-type: none"> <li><input type="checkbox"/> BED</li> <li><input type="checkbox"/> CHAMBER</li> <li><input type="checkbox"/> TRENCH</li> <li><input type="checkbox"/> OTHER: _____</li> </ol>	<p><b>DISPOSAL SYSTEM TO SERVE:</b></p> <ol style="list-style-type: none"> <li><input type="checkbox"/> SINGLE FAMILY DWELLING</li> <li><input type="checkbox"/> MODULAR OR MOBILE HOME</li> <li><input type="checkbox"/> MULTIPLE FAMILY DWELLING</li> <li><input type="checkbox"/> OTHER _____ SPECIFY: _____</li> </ol>	<p><b>TYPE OF WATER SUPPLY</b></p> <p><u>Lake Water</u></p>
<p>SIZE OF PROPERTY: <u>17424</u></p>	<p>ZONING: <u>P11</u></p>	

## DESIGN DETAILS (SYSTEM LAYOUT SHOWN ON PAGE 3)

<p><b>TREATMENT TANK</b></p> <ol style="list-style-type: none"> <li><input type="checkbox"/> SEPTIC: <input type="checkbox"/> Regular <input type="checkbox"/> Low Profile</li> <li><input type="checkbox"/> AEROBIC</li> </ol> <p>SIZE: _____ GALS.</p>	<p><b>WATER CONSERVATION</b></p> <ol style="list-style-type: none"> <li><input type="checkbox"/> NONE</li> <li><input type="checkbox"/> LOW VOLUME TOILET</li> <li><input type="checkbox"/> SEPARATED LAUNDRY SYSTEM</li> <li><input type="checkbox"/> ALTERNATIVE TOILET</li> </ol> <p>SPECIFY: _____</p>	<p><b>PUMPING</b></p> <ol style="list-style-type: none"> <li><input type="checkbox"/> NOT REQUIRED</li> <li><input type="checkbox"/> MAY BE REQUIRED (DEPENDS ON TREATMENT TANK LOCATION AND ELEVATION)</li> <li><input type="checkbox"/> REQUIRED</li> </ol> <p>DOSE: _____ GALS.</p>	<p>CRITERIA USED FOR DESIGN FLOW (BEDROOMS, SEATING, EMPLOYEES, WATER RECORDS, ETC.)</p>				
<p><b>SOIL CONDITIONS USED FOR DESIGN PURPOSES</b></p> <table border="1" style="width: 100%;"> <tr> <th>PROFILE</th> <th>CONDITION</th> </tr> <tr> <td>DEPTH TO LIMITING FACTOR: <u>12.5'</u></td> <td></td> </tr> </table>	PROFILE	CONDITION	DEPTH TO LIMITING FACTOR: <u>12.5'</u>		<p><b>SIZE RATINGS USED FOR DESIGN PURPOSES</b></p> <ol style="list-style-type: none"> <li><input type="checkbox"/> SMALL</li> <li><input type="checkbox"/> MEDIUM</li> <li><input type="checkbox"/> MEDIUM-LARGE</li> <li><input type="checkbox"/> LARGE</li> <li><input type="checkbox"/> EXTRA LARGE</li> </ol>	<p><b>DISPOSAL AREA TYPE/SIZE</b></p> <ol style="list-style-type: none"> <li><input type="checkbox"/> BED _____ Sq. Ft.</li> <li><input type="checkbox"/> CHAMBER _____ Sq. Ft. <input type="checkbox"/> REGULAR <input type="checkbox"/> H-20</li> <li><input type="checkbox"/> TRENCH _____ Linear Ft.</li> <li><input type="checkbox"/> OTHER: _____</li> </ol>	<p>DESIGN FLOW: _____ (GALLONS/DAY)</p>
PROFILE	CONDITION						
DEPTH TO LIMITING FACTOR: <u>12.5'</u>							

## SITE EVALUATOR STATEMENT

SITE EVALUATION WAIVED BY LOCAL OPTION

On \_\_\_\_\_ (date) I conducted a site evaluation for this project and certify that the data reported is accurate. The system I propose is in accordance with the Subsurface Wastewater Disposal Rules.



STATE OF MAINE  
DEPARTMENT OF HUMAN SERVICES  
AUGUSTA, MAINE 04333



MICHAEL R. PETIT  
COMMISSIONER

JOSEPH E. BRENNAN  
GOVERNOR

September 29, 1986

Bryon Farrin  
RFD 3, Box 1073  
Augusta, ME. 04330

Subject: After-the-fact Minimum Lot Size Waiver, George Warnken property,  
Albee Road, Togus Pond, Augusta

Dear Mr. Farrin:

The Division has reviewed your application for a waiver to the minimum lot size. Your lot is approximately 17,424 square feet in size; 20,000 square feet are required.

From the information presented it appears your lot was created in May of 1983, 13 years after the Minimum Lot Size Law was adopted. Therefore the following conditions are to be met as conditions of approval:

- (1). A minimum of a 750 gallon septic tank shall be installed to replace the illegal 500 gallon septic tank, and
- (2). The single family dwelling shall remain seasonal in use until such time as the seasonal conversion criteria can be met.

Failure to comply with one or both of these conditions shall be just cause for revocation of our approval. You must obtain a permit for the septic tank from the plumbing inspector.

Very truly yours,

*James A. Jacobsen*

James A. Jacobsen  
Wastewater and Plumbing Control  
Division of Health Engineering

JAJ/pb

cc: George Soucy, LPI ✓  
Paul Beers, SE

