

APPLICATION AND AGREEMENT

TO WAIVE CERTAIN PROVISIONS OF THE PLUMBING CODE

1. Robert Pomerleau, hereby apply to the Maine State Department of Health and Welfare for permission authorizing the responsible Plumbing Inspector to waive certain provisions of the Plumbing Code for an installation in connection with a dwelling or building at Young Rd., Augusta.

This may include materials, methods, dimensions or conditions not specifically approved by the Plumbing Code. Please draw a brief sketch of the property's location on the back of this form so an inspector can find it. Include landmarks, route numbers and street names.

Section of Code to be waived.	Description of specific waiver.
1. <u>Table A-2</u>	<u>Distance from well to septic tank to be</u>
2.	<u>75 feet instead of 100 ft.</u>
3.	

(If additional space is needed, attach a list)

In all other respects, the installation will comply with the Code. The installation will be made in accordance with the ATTACHED PLAN. A permit is to be issued by the Plumbing Inspector if he is in agreement. The undersigned stipulates that he is the owner and occupant of the building involved and that the building is not for sale in the foreseeable future.. The installation will be made by: _____, License No. _____.

If any defects or inadequacies appear, I will promptly notify the State Department of Health and Welfare and subsequently make such corrections as the Department shall find necessary

Owner's signature Robert P. Pomerleau
~~Richard G. Baber~~

NOTE: A PLAN TO SCALE Winter address 2 MURDOCK ST AUGUSTA
MUST BE ATTACHED Summer address SAME
Telephone 622-9435 Date 7-19-76

THE FOLLOWING TO BE FILLED IN BY THE PLUMBING INSPECTOR

I am (Local), (Alternate) Plumbing Inspector for the town of AUGUSTA. I have examined the plans for the installation described above and I find the building to be in my jurisdiction.

I (do), (do not) recommend the issuance of a special permit for the installation as described above.

Signed Richard G. Baber
Date 7/19/76

Return this form to the Division of Health Engineering, Department of Health and Welfare, Augusta, Maine. NO permit shall be issued for this waiver until the Local Plumbing Inspector receives notification from this office.

MAINE DEPARTMENT OF HEALTH AND WELFARE APPLICATION FOR PRIVATE SEWAGE DISPOSAL PERMIT		(For systems disposing of less than 2000 gallons per day)	This is NOT a permit; this form when completed must be presented to the Local Plumbing Inspector to obtain a permit.		Page 1 of 2
Town Augusta	Street, Road, etc. YOUNG RD If on water body, give name TOSQUEZ RD		Permit No. 008134	Date 7-19-76 7-12-76	
Owner of property Robert Pomerleau			Size of lot 24000 ±	<input checked="" type="checkbox"/> Sq. feet <input type="checkbox"/> Acres	
Name & type of establishment if other than private home			Is lot Zoned? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Type of Zoning Shoreland Resource Protection <input type="checkbox"/> Residential <input type="checkbox"/> Commercial	
Name of applicant Owner's agent Robert Pomerleau			If you plan to use a previous subdivision approval in lieu of site investigation, please submit one of the following: <input type="checkbox"/> Deed restriction on private sewage disposal <input type="checkbox"/> Copy of the subdivision's soils report <input type="checkbox"/> Soils report from a State Agency		
Applicant's address Street, Box, etc. Murdoch St		Tel. No. 622-9635			
Town Augusta		zip code 04330		Subdivision name N/A	
Applicant's signature x Robert L. Pomerleau		Date 7/19/76		Lot No. N/A	

This application is for: New System Expanded System Replacement System Replacement of Treatment Tank Only Disposal Area Only

The water supply for this property is: Dug well, depth _____, lining _____; Drilled well, depth _____, lining _____; Spring Surface water Body, Course— with disinfection, without disinfection. Public Utility, name _____

SITE INVESTIGATION							
Show location of pits and/or borings on sketch on page 2, and refer to completed sample form and Chapter 4 of the Code, II.							
Soil Profile No.	Soil Profile No. T.P.1		Soil Profile No.		Soil Profile No.		
	<input checked="" type="checkbox"/> Pit	<input type="checkbox"/> Boring	<input type="checkbox"/> Pit	<input type="checkbox"/> Boring	<input type="checkbox"/> Pit	<input type="checkbox"/> Boring	
Thickness of each 5'	Organic strata	Organic strata	Organic strata	Organic strata	Organic strata	Organic strata	
	Inches 0	Inches	Inches	Inches	Inches	Inches	
	1st strata DARK BROWN FINE SANDY LOAM	1st strata	1st strata	1st strata	1st strata	1st strata	
	Inches 9 ML	Inches	Inches	Inches	Inches	Inches	
	2nd strata REDISH BROWN FINE SANDY LOAM	2nd strata	2nd strata	2nd strata	2nd strata	2nd strata	
Inches 10 ML	Inches	Inches	Inches	Inches	Inches		
3rd strata OLIVE CLAYEY SILT	3rd strata	3rd strata	3rd strata	3rd strata	3rd strata	3rd strata	
Inches 10 ML	Inches	Inches	Inches	Inches	Inches		
Total Depth of observation hole	Inches 29	Total Depth of observation hole	Inches	Total Depth of observation hole	Inches	Total Depth of observation hole	
Max. Ground water table—mottling	<input type="checkbox"/> None Evident 16 Inches	Max. Ground water table—mottling	<input type="checkbox"/> None Evident Inches	Max. Ground water table—mottling	<input type="checkbox"/> None Evident Inches	Max. Ground water table—mottling	<input type="checkbox"/> None Evident Inches
Impervious layer, clay, etc.	<input type="checkbox"/> None Evident 19 Inches	Impervious layer, clay, etc.	<input type="checkbox"/> None Evident Inches	Impervious layer, clay, etc.	<input type="checkbox"/> None Evident Inches	Impervious layer, clay, etc.	<input type="checkbox"/> None Evident Inches
Bedrock	<input type="checkbox"/> None Evident Inches	Bedrock	<input type="checkbox"/> None Evident Inches	Bedrock	<input type="checkbox"/> None Evident Inches	Bedrock	<input type="checkbox"/> None Evident Inches
Type of Bedrock		Type of Bedrock		Type of Bedrock		Type of Bedrock	
Surface slope	3 %	Surface slope	%	Surface slope	%	Surface slope	%
Soil Group & Condition per Table 9-1 of the Code, II	3C	Soil Group & Condition per Table 9-1 of the Code, II		Soil Group & Condition per Table 9-1 of the Code, II		Soil Group & Condition per Table 9-1 of the Code, II	

On **7-12-76** (date), a site investigation for this project was completed. I supervised this soil evaluation and certify that the results indicated above best represent the soil conditions found. I recommend the following type and size of private sewage disposal system. I also recommend the proposed private sewage disposal system layout and location shown on page 2.

Signature **Gerald C. Pomerleau**
Registration/Certification Number **2909**
Date signed **7-13-76**

Soil Scientist
 Geologist
 Soil Engineer
 Other, must show current letter of certification to LPI

PRIVATE SEWAGE DISPOSAL SYSTEM PROPOSED Show location of system and details on sketches on page 2, and refer to completed sample form

SYSTEM: <input checked="" type="checkbox"/> COMBINED SYSTEM <input type="checkbox"/> SEPARATED SYSTEM If separated system—type of human waste disposal system to be used: <input type="checkbox"/> Sealed Vault Privy <input type="checkbox"/> Open Pit Privy <input type="checkbox"/> Compost Toilet <input type="checkbox"/> Incinerator Toilet <input type="checkbox"/> Chemical Toilet <input type="checkbox"/> Other, describe	TREATMENT TANK: <input checked="" type="checkbox"/> Septic Tank <input type="checkbox"/> Concrete <input type="checkbox"/> Fiberglass <input type="checkbox"/> Metal Manufacturer— Unknown Size in gallons 1000 <input type="checkbox"/> Aerobic Tank Manufacturer— Model No. Size in gallons	SUBSURFACE ABSORPTION AREA		SITE MODIFICATION Fill is <input checked="" type="checkbox"/> required, <input type="checkbox"/> not required Fill will be 39 inches deep max
		<input type="checkbox"/> Trench System: Total trench length N/A <input type="checkbox"/> Bed System Length 70 Width 20 <input type="checkbox"/> Chamber System Number <input type="checkbox"/> Type A <input type="checkbox"/> Single File <input type="checkbox"/> Type F <input type="checkbox"/> Cluster <input type="checkbox"/> Mound System Length Width N/A at base <input type="checkbox"/> Special System Length Width N/A <input type="checkbox"/> Non-discharge System Bed-Length N/A Width Holding Tank Size N/A Gal. Manufacturer <input type="checkbox"/> Alarm device provided, type		<input type="checkbox"/> Very Small <input type="checkbox"/> Small <input type="checkbox"/> Medium <input type="checkbox"/> Medium Large <input checked="" type="checkbox"/> Large <input type="checkbox"/> Extra Large
See Chapter 9 of the Code, II.		DISTANCES <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No: The proposed subsurface absorption area will be located at least 100 feet from any and all wells; springs; surface water bodies and courses (lake, pond, ocean, brook, stream, river); swamps; marshes; and bogs. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No: The proposed subsurface absorption area will be located at least 300 feet from any and all wells and springs producing 2000 gallons or more of water per day and any public water supplies.		


PROPERTY / LOT LOCATION MAP Weeks with P.I. 	FOR THE USE OF LPI ONLY <input type="checkbox"/> Denial: Application is denied for following reasons; portions of the Code II are cited. Form is incomplete (____ pg.) as to <input type="checkbox"/> General info, <input type="checkbox"/> Site Investigation, <input type="checkbox"/> System Proposed, <input type="checkbox"/> Site Plan, <input type="checkbox"/> Disposal System Plan, <input type="checkbox"/> Cross-Section, <input type="checkbox"/> Statement. See Section 2.3. <input type="checkbox"/> Site Investigation indicates site is <input type="checkbox"/> totally unsuitable for disposal system; Sections 4.5 and 9.5, Table 9-1 Group 9 and 10. <input type="checkbox"/> Unsuitable for system proposed; Sections 4.3, 4.6, 9.5, Table 9-1. <input type="checkbox"/> System Proposed does not conform to Code; See Sections 9. <input type="checkbox"/> Site Investigation indicates site modifications are necessary; See Sections <input type="checkbox"/> 4.3, <input type="checkbox"/> 4.4, <input type="checkbox"/> 4.5, <input type="checkbox"/> 8.7. <input type="checkbox"/> Miscellaneous _____ See Section SEE WAIVER <input checked="" type="checkbox"/> Acceptance: Application for permit is approved <input type="checkbox"/> with condition specified, comply with Section _____ <input type="checkbox"/> without condition.
Signed LPI Michael B. Baber Date 7/19/76 HHE - 200 5/75	

APPLICATION FOR PRIVATE SEWAGE DISPOSAL PERMIT
(For systems disposing of less than 2000 gallons per day)

Town <i>STA</i>	Street, Road, etc. <i>Young Rd</i>	Owner of property <i>Robert Tomerlano</i>
	If on water body, give name <i>Togus Rd</i>	


Site Plan

Scale 1" = 100 Ft. or




Private Sewage Disposal Plan

Scale 1" = 20' or



Subsurface Absorption Area Cross-section

Scale: Vertical — 1" = 5' or 1" = 4'
Horizontal — 1" = 20' or 1" = 10'



Statement: (no permit may be issued unless signed)

I certify that all the information submitted to be true and correct; and I understand that issuance of a permit is based upon the information and plans submitted by the applicant. I also understand that any falsification of this application is reason to deny a permit to install a private sewage disposal system and that the permit is valid for a six (6) month period from the date of permit issuance. I understand that no guarantee is intended or implied by reason of any advice or approval given by the Administrative Authority or its agent.

Signature Required
Date: *7/19/76*
Applicant:
Owner: *Robert L. Tomerlano*