

R. N. Sylvester



STATE OF MAINE
DEPARTMENT OF HEALTH AND WELFARE
AUGUSTA, MAINE 04330

DEAN FISHER, M. D.
COMMISSIONER

February 13, 1973

R. N. Sylvester
Route 6
Augusta, ME 04330

Dear Sir:

This office will grant to R. N. Sylvester the right to properly install a holding tank for sewage at the subject address. It is required that the tank be pumped when necessary and that the effluent be taken to a public sewage treatment facility for final disposal, or, if none is available, to a place of disposal approved by the officials of the town where final disposal is to take place.

This right is based upon approval from the officials of the town in which disposal is to take place, and from the officials in the town where the holding tank is to be located, including the health officer. It is also contingent upon purchase of the necessary permits and proper installation to comply with applicable requirements of the Maine Plumbing Code under direction of the Local Plumbing Inspector.

The approval of this office is limited to the installation described by pertinent application and by accompanying plans and description.

Yours very truly,

A handwritten signature in cursive script that reads "James L. Faulkner".

James L. Faulkner, P. E.
Sanitary Engineer
Division of Health Engineering

JLF/tma

cc: R. W. Bean

February 13, 1973
Augusta, Maine

In accordance with the terms of the sale of Lot # 72 Windy Street, Augusta, Maine to R.N. Sylvester, I agree to install the sewer line as soon as weather permits this Spring.

Gladys Veilleux Witness

Joseph A. Veilleux
Joseph A. Veilleux, Seller

Gladys Veilleux Witness

R.N. Sylvester
R.N. Sylvester, Buyer

APPLICATION FOR A SPECIAL PERMIT FOR AN EXPERIMENTAL SYSTEM

I, R. N. SYLVESTER, hereby apply for a special permit
INTERIM owner
from the Maine State Department of Health and Welfare to install a
plumbing system for a dwelling or building, at LOT #72, WINDY STREET,
AUGUSTA, utilizing unapproved materials and methods as
city or town
follows: HOLDING TANK FOR SEWAGE

(If additional space is needed, attach a list.)

In all other respects, the installation will comply with the Code. The installation will be made in accordance with the attached plan. This permit is to be in addition to the permit issued by the Local Plumbing Inspector in accordance with the signed agreement herewith enclosed. The undersigned stipulates that he is the owner and ~~occupant~~ of the building involved, and that the building is ~~not~~ for sale in the foreseeable future, and that the ~~installation will be made by~~ COST OF OPERATION
WILL BE PAID BY _____, Plumber's License No. _____

INTERIM Owner's signature
and address

R. N. Sylvester
146 J
Augusta, Maine

Date 2-13-73

THE FOLLOWING TO BE FILLED IN BY THE PLUMBING INSPECTOR

I am the Local, Alternate, (indicate which) Plumbing Inspector for the town of Augusta. I have examined the plans for the installation described above and I find the building to be in my jurisdiction.

I do, ~~do not~~ (indicate which) recommend that the Maine Department of Health and Welfare issue a special permit for an experimental installation as described above.

Signed:

George J. Smith

Address:

6 Drew St.

Date:

Feb. 13, 1973

A G R E E M E N T

In consideration of a permit from the State Department of Health and Welfare to install ^{A TEMPORARY SEWAGE DISPOSAL FOR} ~~an experimental plumbing system~~ in the dwelling or building at LOT # 72 WINDY ST. AUGUSTA TO BE SOLD TO ~~occupied by the owner and not for sale in the foreseeable future~~ ^{A SYSTEM} utilizing ~~unapproved materials and methods~~ whose full description follows:

2000 gal. above ground tank for temporary sewage disposal
city sewer line is installed

It is hereby agreed by the undersigned that he will install the plumbing system to comply with the following:

1. The installation must receive prior approval of the Local Plumbing Inspector having jurisdiction.
2. The system must be installed in compliance with the requirements of the State Plumbing Code in all aspects other than for the materials and method specified.
3. Dimensions of the system are indicated on an accompanying sketch.
4. The Division of Health Engineering will be notified at least 24 hours before the final test of the system.
5. The Maine Department of Health and Welfare has the right to inspect the installation during installation and at later dates.

If any defects or inadequacies appear, he will promptly notify the State Department of Health and Welfare, and subsequently make such corrections as the Department shall find necessary.

R. M. J. [Signature]
Name of Installer

~~Plumber's License No.~~

Signed: George J. [Signature]
Local Plumbing Inspector

Signed: R. M. J. [Signature]
INTERIM Owner

Date: 2-13-73