

*Dostie, Pamphile*



STATE OF MAINE  
DEPARTMENT OF HUMAN SERVICES  
AUGUSTA, MAINE 04333

DAVID E. SMITH  
COMMISSIONER

June 28, 1977

Mr. Pamphile Dostie  
200 Mt. Vernon Avenue  
Augusta, ME 04330

Subject: Waiver to the Maine Plumbing Code, Part II,  
Dostie Property, Bog Road, Augusta

Dear Mr. Dostie:

This will acknowledge receipt of a waiver request and a plan with soils information by Gerald C. Poulin, Site Evaluator, showing the proposed sewage disposal system for the subject project. It is not in compliance with the Maine Plumbing Code, Part II, because of installation in filled land, the reason for the waiver request.

In consideration of the plan dated October 26, 1975, and recommendations by Mr. Poulin, this office will grant the responsible Local Plumbing Inspector the right to waive certain provisions of the Maine Plumbing Code for the following disposal system under authority of Section 10.3:

The installation of a 1000 gallon septic tank to be followed by a 20'x50' disposal bed.

Approval of this waiver is in no way to be construed as a guarantee of the system's performance.

In all other respects the installation is to comply with the Maine Plumbing Code, Part II, Private Sewage Disposal Regulations and follow the plan submitted with this proposal.

At least 12 inches of fill shall be applied on both the uphill and downhill sides of the bed. This fill shall be of a texture similar to the original soil and will provide the required 24 inch separation between the bottom of the disposal bed and the seasonal high water table and impervious layer. The fill must be extended in all directions as required by Section 8.7 of the Maine Plumbing Code, Part II.


Final approval of the sewage portion is subject to permit by the Local Plumbing Inspector before the construction of this system. A completed HHE-200 Form must be submitted to him for processing. The

Mr. Pamphile Dostie

June 28, 1977

inspector is to be notified before covering the work, and the work is to be left uncovered until his inspection. He shall be supplied with copies of approved plans for his reference at inspection. Approval is also subject to any local ordinances and state laws.

Yours very truly,



J. Bruce Johnson, Sanitary Engineer  
Plans and Standards Review  
Division of Health Engineering

JBj/mm

cc: Richard Baker, LPI ✓  
Gerald Poulin  
encl.

DUPLICATE — To be retained by the Plumbing Inspector

|  |   |  |  |   |   |
|--|---|--|--|---|---|
| MAINE DEPARTMENT OF HEALTH AND WELFARE<br>APPLICATION FOR PRIVATE SEWAGE DISPOSAL PERMIT   |   | (For systems disposing of less than 2000 gallons per day)  | This is NOT a permit; this form when completed must be presented to the Local Plumbing Inspector to obtain a permit. |   | Page 1 of 2   |
| Town<br><i>Augusta</i>   | Street, Road, etc. <i>Bog Road</i><br>If on water body, give name |  | Permit No.<br><i>22821M</i>  | Date<br><i>6-29-77</i>  |   |
| Owner of property<br><i>Pamphil Dostie</i>   |   | Owner's address  |  | Size of lot<br><i>1 1/2</i> #   | <input type="checkbox"/> Sq. feet<br><input type="checkbox"/> Acres |
| Name & type of establishment if other than private home  |   | Is lot Zoned? <input type="checkbox"/> Yes <input type="checkbox"/> No   | Type of Zoning<br><i>N/A</i>   | <input type="checkbox"/> Residential<br><input type="checkbox"/> Commercial<br><input type="checkbox"/> Resource Protection |   |
| Name of applicant<br>Owner's agent<br><i>Pamphil Dostie</i>  |   | If you plan to use a previous subdivision approval in lieu of site investigation, please submit one of the following:<br><input type="checkbox"/> Deed restriction re. private sewage disposal<br><input type="checkbox"/> Copy of the subdivision's soils report<br><input type="checkbox"/> Soils report from a State Agency |  |   |   |
| Applicant's address<br>Street, Box, etc.<br><i>MT VERNON AVE</i>   |   | Tel. No.<br><i>622-1531</i>  |  |   |   |
| Town<br><i>Augusta</i>   | Maine<br><i>04330</i>   |  | Subdivision name<br><i>N/A</i>   | Lot No.<br><i>N/A</i>   |   |
| Applicant's signature<br><i>Pamphil Dostie</i>   |   | Date<br><i>6-29-77</i>   |  |   |   |
| Owner's signature<br><i>Pamphil Dostie</i>   |   | Date<br><i>6-29-77</i>   |  |   |   |
| This application is for: <input type="checkbox"/> New System <input type="checkbox"/> Expanded System <input type="checkbox"/> Replacement System <input type="checkbox"/> Replacement of <input type="checkbox"/> Treatment Tank Only <input type="checkbox"/> Disposal Area Only |   |  |  |   |   |
| The water supply for this property is: <input type="checkbox"/> Dug well, depth _____, lining _____; <input type="checkbox"/> Drilled well, depth <i>PROP.</i> , lining _____; <input type="checkbox"/> Spring <input type="checkbox"/>  |   |  |  |   |   |
| depth _____, lining _____; Surface water <input type="checkbox"/> Body, <input type="checkbox"/> Course— <input type="checkbox"/> with disinfection, <input type="checkbox"/> without disinfection. <input type="checkbox"/> Public Utility, name _____                            |   |  |  |   |   |

**SITE INVESTIGATION** Show location of pits and/or borings on sketch on page 2, and refer to completed sample form and Chapter 4 of the Code, II.

| Thickness and Description of each strata encountered | Soil Profile No.  |                                 | Soil Profile No.                                     |   | Soil Profile No.                                     |   | Soil Profile No.                                     |   | Soil Profile No.                                     |   |
|--|---|---------------------------------|--|---|--|---|--|---|--|---|
|  | <input type="checkbox"/> Pit                              | <input type="checkbox"/> Boring | <input type="checkbox"/> Pit                         | <input type="checkbox"/> Boring                 | <input type="checkbox"/> Pit                         | <input type="checkbox"/> Boring                 | <input type="checkbox"/> Pit                         | <input type="checkbox"/> Boring                 | <input type="checkbox"/> Pit                         | <input type="checkbox"/> Boring                 |
| Organic strata                                       |   |                                 | Organic strata                                       |   | Organic strata                                       |   | Organic strata                                       |   | Organic strata                                       |   |
| Inches <i>0</i>                                      |   |                                 | Inches   |   | Inches   |   | Inches   |   | Inches   |   |
| 1st strata <i>CLAY &amp; GRAVEL WITH FILL</i>        |   |                                 | 1st strata   |   | 1st strata   |   | 1st strata   |   | 1st strata   |   |
| Inches <i>30</i>                                     |   |                                 | Inches   |   | Inches   |   | Inches   |   | Inches   |   |
| 2nd strata <i>BROWN SILTY LOAM WITH AL</i>           |   |                                 | 2nd strata   |   | 2nd strata   |   | 2nd strata   |   | 2nd strata   |   |
| Inches   |   |                                 | Inches   |   | Inches   |   | Inches   |   | Inches   |   |
| 3rd strata <i>OLIVE SILTY CLAY</i>                   |   |                                 | 3rd strata   |   | 3rd strata   |   | 3rd strata   |   | 3rd strata   |   |
| Inches <i>20" CL</i>                                 |   |                                 | Inches   |   | Inches   |   | Inches   |   | Inches   |   |
| Total Depth of observation hole                      | Inches <i>58</i>  |                                 | Total Depth of observation hole                      | Inches  |
| Max. Ground water table—mottling                     | <input type="checkbox"/> None Evident<br><i>38</i> Inches |                                 | Max. Ground water table—mottling                     | <input type="checkbox"/> None Evident<br>Inches | Max. Ground water table—mottling                     | <input type="checkbox"/> None Evident<br>Inches | Max. Ground water table—mottling                     | <input type="checkbox"/> None Evident<br>Inches | Max. Ground water table—mottling                     | <input type="checkbox"/> None Evident<br>Inches |
| Impervious layer, clay, etc.                         | <input type="checkbox"/> None Evident<br><i>38</i> Inches |                                 | Impervious layer, clay, etc.                         | <input type="checkbox"/> None Evident<br>Inches | Impervious layer, clay, etc.                         | <input type="checkbox"/> None Evident<br>Inches | Impervious layer, clay, etc.                         | <input type="checkbox"/> None Evident<br>Inches | Impervious layer, clay, etc.                         | <input type="checkbox"/> None Evident<br>Inches |
| Bedrock  | <input type="checkbox"/> None Evident                     |                                 | Bedrock  | <input type="checkbox"/> None Evident           |
| Type of Bedrock                                      |   |                                 | Type of Bedrock                                      |   | Type of Bedrock                                      |   | Type of Bedrock                                      |   | Type of Bedrock                                      |   |
| Surface slope  | <i>1</i> %  |                                 | Surface slope  | %   |
| Soil Group & Condition per Table 9-1 of the Code, II |   |                                 | Soil Group & Condition per Table 9-1 of the Code, II |   | Soil Group & Condition per Table 9-1 of the Code, II |   | Soil Group & Condition per Table 9-1 of the Code, II |   | Soil Group & Condition per Table 9-1 of the Code, II |   |

On *10-26-75* (date), a site investigation for this project was completed. I supervised this soil evaluation and certify that the results indicated above best represent the soil conditions found. I recommend the following type and size of private sewage disposal system. I also recommend the proposed private sewage disposal system layout and location shown on page 2.

Signature *Gerald C. Havelin*  
Registration/Certification Number *2909*  
Date signed *10-26-75*




Soil Scientist  
 Geologist  
 Soil Engineer  
 Other, must show current letter of certification to LPI

**PRIVATE SEWAGE DISPOSAL SYSTEM PROPOSED** Show location of system and details on sketches on page 2, and refer to completed sample form.

|   |  |   |  |  |
|---|--|---|--|--|
| <b>SYSTEM:</b><br><input checked="" type="checkbox"/> COMBINED SYSTEM<br><input type="checkbox"/> SEPARATED SYSTEM<br>If separated system—type of human waste disposal system to be used:<br><input type="checkbox"/> Sealed Vault Privy<br><input type="checkbox"/> Open Pit Privy<br><input type="checkbox"/> Compost Toilet<br><input type="checkbox"/> Incinerator Toilet<br><input type="checkbox"/> Chemical Toilet<br><input type="checkbox"/> Other, describe<br><br>See Chapter 9 of the Code, II. | <b>TREATMENT TANK:</b><br><input checked="" type="checkbox"/> Septic Tank<br><input type="checkbox"/> Concrete<br><input type="checkbox"/> Fiberglass<br><input type="checkbox"/> Metal<br>Manufacturer—<br><i>UNKNOWN</i><br>Size in gallons<br><i>1000</i><br><br><input type="checkbox"/> Aerobic Tank<br>Manufacturer—<br>Model No.<br>Size in gallons | <b>SUBSURFACE ABSORPTION AREA</b>   |  | <b>SITE MODIFICATION</b><br>Fill is— <input checked="" type="checkbox"/> required, <input type="checkbox"/> not required<br>Fill will be <i>12</i> inches deep   |
|   |  | Type<br><input type="checkbox"/> Trench System: Total trench length <i>21 ft</i><br><input type="checkbox"/> Bed System<br>Length <i>50</i> Width <i>20</i><br><input type="checkbox"/> Chamber System<br>Number <i>N/A</i><br><input type="checkbox"/> Type A <input type="checkbox"/> Single File<br><input type="checkbox"/> Type F <input type="checkbox"/> Cluster<br><input type="checkbox"/> Mound System<br>Length _____ Width _____ at base<br><input type="checkbox"/> Special System<br>Length _____ Width _____<br><input type="checkbox"/> Non-discharge System<br>Bed-Length _____ Width _____<br>Holding Tank Size _____ Gal. Manufacturer _____<br><input type="checkbox"/> Alarm device provided, type _____ | SIZE<br><input type="checkbox"/> Very Small<br><input type="checkbox"/> Small<br><input type="checkbox"/> Medium<br><input checked="" type="checkbox"/> Medium Large<br><input type="checkbox"/> Large<br><input type="checkbox"/> Extra Large | <b>DETAILS</b><br><input type="checkbox"/> A Distribution Box is required<br>Pumping is— <input type="checkbox"/> required, <input checked="" type="checkbox"/> is not required.<br>The Dose will be _____ gallons |

|                                 |   |
|---------------------------------|---|
| PROPERTY / LOT LOCATION MAP<br> | <b>FOR THE USE OF LPI ONLY</b><br><input type="checkbox"/> Denial: Application is denied for following reasons; portions of the Code II are cited. Form is incomplete ( _____ pg.) as to <input type="checkbox"/> General info, <input type="checkbox"/> Site Investigation, <input type="checkbox"/> System Proposed, <input type="checkbox"/> Site Plan, <input type="checkbox"/> Disposal System Plan, <input type="checkbox"/> Cross-Section, <input type="checkbox"/> Statement. See Section 2.3.<br><input type="checkbox"/> Site Investigation indicates site is <input type="checkbox"/> totally unsuitable for disposal system; Sections 4.5 and 9.5, Table 9-1 Group 9 and 10. <input type="checkbox"/> Unsuitable for system proposed; Sections 4.3, 4.6, 9.5, Table 9-1.<br><input type="checkbox"/> System Proposed does not conform to Code; See Sections 9.<br><input type="checkbox"/> Site Investigation indicates site modifications are necessary; See Sections <input type="checkbox"/> 4.3, <input type="checkbox"/> 4.4, <input type="checkbox"/> 4.6, <input type="checkbox"/> 8.7.<br><input checked="" type="checkbox"/> Miscellaneous <i>Approved by STATE 6-28-77</i> See Section _____<br><input checked="" type="checkbox"/> Acceptance: Application for permit is approved <input type="checkbox"/> with condition specified, comply with Section _____<br><input type="checkbox"/> without condition.<br>Signed LPI <i>Michael E. Baker</i> Date <i>6-29-77</i> HHE-200 7/74 |
|---------------------------------|---|

(For systems disposing of less than 2000 gallons per day)



Statement: (no permit may be issued unless signed)

I certify that all the information submitted to be true and correct; and I understand that issuance of a permit is based upon the information and plans submitted by the applicant. I also understand that any falsification of this application is reason to deny a permit to install a private sewage disposal system and that the permit is valid for a six (6) month period from the date of permit issuance. I understand that no guarantee is intended or implied by reason of any advice or approval given by the Administrative Authority or its agent.

Signature Required HHE-200 7/72

Date: 6-29-77  
 Applicant: \_\_\_\_\_  
 Owner: Ramphal Postle