ALLENWOOD PARK

PERCOLATION TESTS BY LEON ALLEN JUNE 2-3 1972

TEST NO. & LOCATION	INCH DROP	NO. OF MIN.	MIN. PER INCH
#1 LOT NO. 11	5	180	36
	SOIL - silty fine sand WITH ROCKS - SATURATED		
#2 LOT NO. 16	10	65	6.5
	SOIL - silty Coarse sand and Rock - WET		
#3 LOT NO. 19	8	85	10.6
	SOIL - same as TEST #2		
#4 LOT NO. 7 B.	6	105	17.5
	SOIL - DENSE SILT WITH ROCKS - SATURATED		
#5 LOT - 2.B.	11	40	3.6
	SOIL - SILTY COARSE GRAVEL		wet

Guy Allen
Lane Surveyor 175