SUBMIT THE FOLLOWING COMPLETED FORM TO YOUR LOCAL PLUMBING INSPECTOR

Peter Laferriere

DATE 8-11-73
NUMBER OF BEDROOMS 2
SIZE OF SEPTIC TANK 1000 gals
TYPE OF SOIL Sandy Clay

OWNER Peter Laferriere Lot 23
STREET 29 Franklin Street
CITY Augusta MAINE
TEL. NUMBER 622-3695

Test Performed by Donald E. White

Local Plumbing Inspector's Signature

LOCATION OF PROPOSED INSTALLATION
STREET Cecile Avenue
CITY Augusta MAINE
TEL. NUMBER

SKETCH: LOCATION OF BUILDING DISPOSAL SYSTEM, TERRAIN FEATURES, PERCOLATION HOLES, WATER SUPPLIES, ETC.



_____ Depth to Water Table
_____ Depth to Bedrock
_____ Depth to Clay or other impervious strata

REMARKS

HOLE	HOLE DEPTH	TIME		DEPTH OF WATER SURFACE		ELAPSED TIME	TOTAL DROP OF WATER	PERCOL. RATE MINUTES/INCH
		START	FINISH	START	FINISH			
#1	36 in.	11:05	11:33	30 in.	34 in.	28 min.	4 in.	7.0 min/in
#2	36 in.	11:12	11:22	30 in.	34 in.	10 min.	4 in.	2.5 min/in
#3	36 in.	11:09	11:20	30 in.	34 in.	11 min.	4 in.	2.75 min/in
#4	36 in.	11:03	11:39	30 in.	34 in.	36 min.	4 in.	9.0 min/in
						AVERAGE RATE		5.3 min/in