Farrin, Harvey

STATE OF MAINE
DEPARTMENT OF HEALTH AND WELFARE
AUGUSTA, MAINE 04330

DEAN FISHER, M. D.
COMMISSIONER

THIS DID NOT GO THROUGH

June 28, 1972

THEY WANT BACK OVER THE HILL AND FOUND GOOD SOIL

C. J. Morton - PS. YOU SHOULD HAVE THE 2ND ONE

Mr. Oliver Coulling, P.E.
25 Wade St.
Augusta, ME 04330

Subject: Percolation Test for Harvey Farrin
North Belfast Avenue, Augusta
Made June 15, 1972

Dear Mr. Coulling:

After review of the subject percolation test, we find that it does not appear to have been made in compliance with instructions in the Code. The rate is to be measured in the bottom six inches of the hole.

It is important that the directions be followed carefully, otherwise, the test results are not reliable and may not be acceptable.

Yours very truly,

Earle W. Tibbetts, Director
Division of Health Engineering

JLF/tma

cc: Charles Morton, L.P.I.