

69-3

SUBSURFACE WASTEWATER DISPOSAL SYSTEM APPLICATION

PROPERTY ADDRESS

Town Or Plantation: Augusta

Street: Wendell Road

Subdivision Lot #: 10

PROPERTY OWNERS NAME

Last: Dipisa First: William

Applicant Name: William Dipisa

Mailing Address of Owner/Applicant (if Different): Box 516, 100 Main Street, Augusta, ME 04401

AUGUSTA PERMIT # 1,414 TOWN COPY

Date Permit Issued: 8/15/89 \$ 201.00 if Double Fee Charged

FEE: 201.00

L.P.I. # 188

Local Plumbing Inspector Signature

Owner/Applicant Statement

I certify that the information submitted is correct to the best of my knowledge and understand that any falsification is reason for the Local Plumbing Inspector to deny a Permit.

Signature of Owner/Applicant: William Dipisa Date: 8/2/89

Caution: Inspection Required

I have inspected the installation authorized above and found it to be in compliance with the Subsurface Wastewater Disposal Rules.

Local Plumbing Inspector Signature: Ray F. Lullu Date Approved: Aug 2, 1989

PERMIT INFORMATION

THIS APPLICATION IS FOR:

- NEW SYSTEM
- REPLACEMENT SYSTEM
- EXPANDED SYSTEM
- SEASONAL CONVERSION
- EXPERIMENTAL SYSTEM

THIS APPLICATION REQUIRES:

- NO RULE VARIANCE REQUIRED
- NEW SYSTEM VARIANCE
Attach New System Variance Form
- REPLACEMENT SYSTEM VARIANCE
Attach Replacement System Variance Form
- Requires only Local Plumbing Inspector Approval
- Requires both State and Local Plumbing Inspector Approval

INSTALLATION IS COMPLETE SYSTEM

- NON-ENGINEERED SYSTEM
- PRIMITIVE SYSTEM (Includes Alternative Toilet)
- ENGINEERED (+ 2000 gpd)

INDIVIDUALLY INSTALLED COMPONENTS:

- TREATMENT TANK (ONLY)
- HOLDING TANK
- ALTERNATIVE TOILET (ONLY)
- NON-ENGINEERED DISPOSAL AREA (ONLY)
- ENGINEERED DISPOSAL AREA (ONLY)
- SEPARATED LAUNDRY SYSTEM

IF REPLACEMENT SYSTEM:

YEAR FAILING SYSTEM INSTALLED: _____

THE FAILING SYSTEM IS:

- BED
- CHAMBER
- TRENCH
- OTHER

DISPOSAL SYSTEM TO SERVE:

- SINGLE FAMILY DWELLING
- MODULAR OR MOBILE HOME
- MULTIPLE FAMILY DWELLING
- OTHER _____ SPECIFY _____

SIZE OF PROPERTY: _____

ZONING: _____

TYPE OF WATER SUPPLY

Treated supply

DESIGN DETAILS (SYSTEM LAYOUT SHOWN ON PAGE 3)

TREATMENT TANK

- SEPTIC: Regular Low Profile
- AEROBIC

SIZE: 450 GALS.

WATER CONSERVATION

- NONE
- LOW VOLUME TOILET
- SEPARATED LAUNDRY SYSTEM
- ALTERNATIVE TOILET

SPECIFY: _____

PUMPING

- NOT REQUIRED
- MAY BE REQUIRED (DEPENDENT ON TREATMENT TANK LOCATION AND ELEVATION)
- REQUIRED

DOSE: _____ GALS.

CRITERIA USED FOR DESIGN FLOW (BEDROOMS, SEATING, EMPLOYEES, WATER RECORDS, ETC.)

N/A

DESIGN FLOW: _____ (GALLONS/DAY)

SOIL CONDITIONS USED FOR DESIGN PURPOSES

PROFILE: _____ CONDITION: _____

DEPTH TO LIMITING FACTOR: _____

SIZE RATINGS USED FOR DESIGN PURPOSES

- SMALL
- MEDIUM
- MEDIUM-LARGE
- LARGE
- EXTRA LARGE

DISPOSAL AREA TYPE/SIZE

- BED _____ Sq. Ft.
- CHAMBER _____ Sq. Ft.
- TRENCH _____ Linear Ft.
- OTHER: _____

SITE EVALUATOR STATEMENT

SITE EVALUATION WAIVED BY LOCAL OPTION

On _____ (date) I conducted a site evaluation for this project and certify that the data reported is accurate. The system I propose is in accordance with the Subsurface Wastewater Disposal Rules.

Site Evaluator or Professional Engineer's Signature: _____ SE# / PE# _____ Date: _____

* Local Plumbing Inspector's Signature if a Local Site Evaluation Waiver under a Local Option

William W. Rideout

LICENSED EVALUATOR - CERTIFIED GEOLOGIST

RFD 1 BOX 5880, GARDINER, MAINE 04345

207 582-4161

Mr. William Duplisea
R-1, B-2886
Windsor, Maine 04363

August 12, 1987

Re: Septic System, Woodard Road, Augusta, Maine

Dear Mr. Duplisea:


I have reviewed your plan to add a toilet and lavatory in your garage and pump the waste water to the existing tank. This project would provide sleeping space for guests during the summer months. I have also reviewed this with Mr. Jay Hardcastle, Department of Human Services, Division of Health Engineering, Augusta.

The existing system is designed for a four bedroom home with up to eight people. In view of the small size of the bedrooms and that no more than eight people would be staying on the property and using the septic system we feel that there is no problem with your plans.

You will need a 750 gallon septic tank at the garage and an additional pump may be required. If an additional pump is required it must not pump to the house septic tank but rather to the house pump station or directly to the bed. I would recommend that the additional pump go to the house pump station to avoid excavating into the septic system. I also recommend the installation of a low volume toilet and spring loaded faucets on the lavatory to minimize water useage.

If I can be of further assistance, please call.

Yours truly,


William W. Rideout, L.E.#51